



TYPICAL NORMAL BEDDING

OVERWIDTH BEDDING

SEE NOTE 2

NOTES:

1. TRENCH WIDTH AT THE UPPER LIMIT OF THE PIPE ZONE SHALL BE WITHIN THE FOLLOWING LIMIT FOR TYPICAL NORMAL BEDDING.
 - (A) MAXIMUM TRENCH WIDTH - O.D. PIPE OR BELL PLUS 8" MAX. EACH SIDE OF PIPE.
 - (B) MINIMUM TRENCH WIDTH - O.D. PIPE OR BELL PLUS 6" MIN. EACH SIDE OF PIPE.
2. OVERWIDTH BEDDING SHALL BE USED WHERE THE TRENCH WIDTH AT THE UPPER LIMIT OF THE PIPE ZONE EXCEEDS THE MAXIMUM WIDTH SPECIFIED ABOVE.
3. MAXIMUM OVERWIDTH BEDDING TO BE DETERMINED IN FIELD BY CITY ENGINEER ON THE BASIS OF OVERWIDTH EXCAVATED.
4. IF UNSTABLE SOIL IS ENCOUNTERED, CITY ENGINEER SHALL DETERMINE DEPTH OF REMOVAL AND SIZE OF FOUNDATION ROCK REFILL MATERIAL.
5. RESURFACING OF TRENCH PAVEMENT SHALL BE PER BREA STD PLAN 102.



CITY OF BREA

APPROVED:

[Signature]
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER

219-0

SHEET 1 OF 1